



INSTITUT TECHNOLOGIQUE

Bordeaux, July 25th 2016

CASCO ADHESIVES AB
M. Lars Hjelm
PO Box 11538
SE-10061 STOCKHOLM

Our ref. : LBO/GL/MP/403/16/364-e

Project manager : *Guillaume LEGRAND*

☎ 00.33.5 56 43 64 48

✉ guillaume.legrand@fcba.fr

Scope : **TYPE I CLASSIFICATION ACCORDING TO NF EN 301 (2013)
OF THE TWO COMPONENTS MUF ADHESIVE SYSTEM
1247-2526**

Dear Sir,

I hereby confirm that the two components MUF adhesive system reference 1247/2526:

- Fulfils to the Type I classification requirements of the NF EN 301 (2013) standard for the bonding of load bearing timber structures. Conditions approved :
 - Finger jointing and face gluing with mix-in application of resin and hardener with ratios 100 / 20 to 100 /100
Classification designation according to NF EN 301 (2013) :
EN 301 I 90 GP 0.6 M
- And fulfils to the requirements of the NF EN 14080 (2013) standard for the production of glued laminated timber.

Siège social
10, rue Galilée
77420 Champs sur Mame
Tél +33 (0)1 72 84 97 84

Bordeaux
Allée de Boutaut - BP 227
33028 Bordeaux Cedex
Tél +33 (0)5 56 43 63 00
Fax +33 (0)5 56 43 64 80

www.fcba.fr

Siret 775 680 903 00132
APE 7219 Z
Code TVA CEE : FR 14 775 680 903



INSTITUT TECHNOLOGIQUE

This approval is based on the following documents:

- Approval letter and associated classification reports according to NF EN 301 (2006) FCBA n° CTBA-IBC/FS/68/06.367, PC/FS/68.05.467, et PC/FS/68.05.468
- Additional classification report according to NF EN 301 (2013) FCBA n° LBO/GL/MP/403/16/364

Sincerely yours,

Guillaume LEGRAND



INSTITUT
TECHNOLOGIQUE www.fcba.fr

Bordeaux
Allée de Boutaut / BP 227
33028 Bordeaux Cedex
Tél +33 (0)5 56 43 63 00
Fax +33 (0)5 56 43 64 80

**Engineer in charge of the approval of adhesives
for the bonding of wood**